



SCHEDULE OF ITEMS			
ITEM NO.	DESCRIPTION	ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17	8	BALL VALVE
3	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM	9	LINE STRAINER
4	POLYETHYLENE TO COPPER CONNECTOR	10	HIGH HAZARD TESTABLE BACKFLOW PREVENTION DEVICE
5	DEPTH - MINIMUM COVER AUST. STANDARD AS/NZS 3500.1 AND LOCAL COUNCIL REQUIREMENTS	11	ELBOW
6	20mm / 25mm RIGHT ANGLE BALL VALVE	12	TIMBER STAKE
7	20mm / 25mm APPROVED WATER CORPORATION SUPPLIED WATER METER	13	HOSE BIB TAP
		14	HOSE CONNECTION VACUUM BREAKER
		15	TUBE BUSH
		16	BRASS PLUG

SEE GENERAL NOTES FOR FURTHER INFORMATION

STANDARD LEGEND		
⊗	V	Valve
○	M	Meter
□	D.B.	Dirt Box
—	S.P.	Straight Piece
⊥	T.F.	Testing Ferrule
▭	L.S.	Line Strainer
⌌	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V.T	Single Check Valve Testable
⌌	S.C.D.A.T.	Single Check Detector Assembly Testable

