



TYPICAL ARRANGEMENT - SECTION
NOT TO SCALE

NOTES

1. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE NOTED
2. PROVIDED AND CONNECT ELECTRICAL SUPPLY, ELECTRICAL CONTROLS AND ALARMS TO SPECIFICATIONS USED. APPROVED ITEMS ONLY.
3. PROVIDE AND CONNECT ALL SANITARY DRAINAGE TO AS 3500
4. MIN 1000 CLEAR SPACE AROUND COLLECTION / PUMP UNIT
5. MIN 1800 CLEAR ABOVE COLLECTION / PUMP UNIT
6. REFER TO MRWA WEB PORTAL FOR APPROVED PIPES AND FITTINGS.

| | | | |
|-----------|------------------|-----------|---------------|
| DESIGNED: | C. RADFORD | DATE: | JAN 2009 |
| DRAWN: | D.T. | DATE: | 09/11/09 |
| CHECKED: | INITIALS DATE | APPROVED: | INITIALS DATE |
| 1 | CWW CR 22/08/12 | CWW R.J. | 22/08/12 |
| 0 | SEW S.S. 7/08/12 | SEW C.P. | 7/08/12 |
| REV | DESCRIPTION | DATE | APP.D |
| | 1 | 2 | 3 |

MELBOURNE RETAIL WATER AGENCIES

**PRESSURE SEWER SYSTEM
ON-PROPERTY LAYOUT
COMMERCIAL / INDUSTRIAL**

| | | |
|--------------|------------|-----|
| SCALE: | N.T.S | @A3 |
| SHEET: | 1 OF 1 | |
| DRAWING No.: | PSS-1111-M | REV |
| | | 3 |