



STANDARD LEGEND

⊗	V	Valve
○	M	Meter
□	D.B.	Dirt Box
---	S.P.	Straight Piece
▭	L.S.	Line Strainer
⌌	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V.T.	Single Check Valve Testable
⌌	S.C.D.A.T.	Single Check Detector Assembly Testable

SCHEDULE OF ITEMS

ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	GATE / BALL VALVE
4	32mm - 50mm DIRT BOX WATER CORPORATION SUPPLIED
5	APPROVED WATER CORPORATION SUPPLIED WATER METER
6	LOW HAZARD NON-TESTABLE BACKFLOW PREVENTION DEVICE
7	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM
8	POLYETHYLENE TO COPPER CONNECTOR
SEE GENERAL NOTES FOR FURTHER INFORMATION	

GENERAL NOTES:

- A. METERS 50MM AND ABOVE TO BE SUPPORTED INDEPENDENT OF PIPEWORK
- B. NO CONNECTION PERMITTED BETWEEN WATER METER AND BACKFLOW DEVICE
- C. WATER CORPORATION IS RESPONSIBLE FOR MAINTENANCE TO THE OUTLET OF THE MAIN WATER METER
- D. METER CONNECTION MAY BE SCREWED OR FLANGED

DRAWING NUMBER:

4

SCALE:

NOT TO SCALE

DATE:

SEPTEMBER 2024

32 - 50mm GENERAL WATER SERVICE
LOW HAZARD
RESIDENTIAL / COMMERCIAL
TYPICAL ARRANGEMENT

