



SCHEDULE OF ITEMS

ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	GATE / BALL VALVE
4	32mm - 50mm DIRT BOX WATER CORPORATION SUPPLIED
5	APPROVED WATER CORPORATION SUPPLIED WATER METER
6	LOW HAZARD NON-TESTABLE BACKFLOW PREVENTION DEVICE
7	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM
8	POLYETHYLENE TO COPPER CONNECTOR
SEE GENERAL NOTES FOR FURTHER INFORMATION	

GENERAL NOTES:

- A. METERS 50MM AND ABOVE TO BE SUPPORTED INDEPENDENT OF PIPEWORK
- B. NO CONNECTION PERMITTED BETWEEN WATER METER AND BACKFLOW DEVICE
- C. WATER CORPORATION IS RESPONSIBLE FOR MAINTENANCE TO THE OUTLET OF THE MAIN WATER METER
- D. METER CONNECTION MAY BE SCREWED OR FLANGED

DRAWING NUMBER:
4

SCALE:
NOT TO SCALE

DATE:
DECEMBER 2021

32 - 50mm GENERAL WATER SERVICE
LOW HAZARD
RESIDENTIAL / COMMERCIAL
TYPICAL ARRANGEMENT

