



STANDARD LEGEND

⊗	V	Valve
○	M	Meter
□	D.B.	Dirt Box
—	S.P.	Straight Piece
▭	L.S.	Line Strainer
⌌	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V.T	Single Check Valve Testable
⌌	S.C.D.A.T.	Single Check Detector Assembly Testable

SCHEDULE OF ITEMS

ITEM NO.	DESCRIPTION	ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17	7	SPACER 3 x PIPE DIAMETER
3	ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE	8	STRAINER TO CONFORM TO BACKFLOW PREVENTION DEVICE MANUFACTURER'S REQUIREMENTS
4	DIRT BOX WATER CORPORATION SUPPLIED	9	HIGH / MEDIUM TESTABLE BACKFLOW PREVENTION DEVICE NOTE: MIN HEIGHT 300mm TO DISCHARGE PORT
5	SPACER 5 x PIPE DIAMETER		
6	APPROVED WATER CORPORATION SUPPLIED WATER METER		

SEE GENERAL NOTES FOR FURTHER INFORMATION

GENERAL NOTES:

A. Meters 50mm and above to be supported independent of pipework

B. No connection permitted between water meter and backflow device

C. Water corporation is responsible for maintenance to the outlet of the main water meter