



SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE (RESILIENT SEATED)
4	SPACER 5 x PIPE DIAMETER
5	MAGNETIC WATER METER. SUPPLIED BY WATER CORPORATION. DIRT BOX NOT REQUIRED
6	SPACER 3 x PIPE DIAMETER
7	SINGLE CHECK VALVE TESTABLE
8	WATER METER FOR GENERAL SERVICE
9	APPROPRIATE BFD
SEE GENERAL NOTES FOR FURTHER INFORMATION	

GENERAL NOTES:

- A. METERS 50MM AND ABOVE TO BE SUPPORTED INDEPENDENT OF PIPEWORK
- B. NO CONNECTION PERMITTED BETWEEN WATER METER AND BACKFLOW DEVICE
- C. METER CONNECTION MAY BE SCREWED OR FLANGED
- D. FOR DETAILS OF GENERAL WATER VALVING ARRANGEMENTS SEE DRAWING NUMBERS 1 – 7
- E. ELECTRO MAGNETIC WATER METERS REQUIRE 240VOLT POWER SUPPLY WHERE SPECIFIED BY THE WATER CORPORATION